LED FLOOD LIGHT




| Version | Nominal Wattage W | Fixture Dimension mm | Fixture Weight kg | Packing Type units /ctn | EPA m² |
|---------|----------------------|-------------------------|----------------------|----------------------------|-----------|
| Small | 30 /40 /50 | 345 x226 x81 | 2.3(±0.1) | 1 | 0.094 |
| Medium | 60 /80 /100 /120 | 447 x311 x90 | 4.4(±0.1) | 1 | 0.172 |
| Large | 150 /180 /200 /240 | 495 x378 x90 | 6.0(±0.1) | 1 | 0.225 |


| VOLTS | AC 100-240V /277V 50 /60Hz | | |
|-------------------|---|--|--|
| PROTECTION CLASS | Class I (Default) /Class II | | |
| POWER FACTOR | >0.95 | | |
| OPERATING TEMP. | -40°C ~ +50°C | | |
| BEAM ANGLE | 25°,60°,90°,110° or Asymmetrical | | |
| HOUSING | High pressure die-cast aluminum Tempered glass | | |
| HOUSING COLOR | Gray (Default) / Black (available on request) | | |
| MOUNTING | Bracket mounted | | |
| Mounting Location | Wall /Pole /Floor /Ceiling | | |
| IP RATING | IP66 | | |
| IK RATING | IK10 | | |
| WARRANTY | 5 years | | |

BRACKET MOUNTING & CONNECTION INSTRUCTIONS

STEP 1: Open the packaging and check the product. In case of any damage, contact us.
STEP 2: Adjust the flood light to direct the light in the desired direction before tightening the screws.
STEP 3: Be sure to connect the cable correctly. Brown-Live, Blue- Neutral, Yellow/Green- -Ground.
STEP 4: Switch the voltage on and check to see that the flood light works properly.
Maintenance: Toolless open clips of the light body then replace the LED or Driver.
Recommended torque: 17Nm ± 1Nm









CAUTION

- Installation and maintenance must be performed by professionals only.
- Please ensure the holder is strong enough and the screws are tightened.
- The ground wire must be securely connected.
- Please make sure the lamp is working with correct input voltage.

- Cut off the power before maintenance.
- Do not use chemicals or corrosive cleaner to clean the fixture.
- If the external flexible cable or cord of this luminaire is damaged, it shall be exclusively replaced by qualfied person in order to avoid a hazard.